

DISTRICT WATER TESTING LABORATORY, BATHINDA
Water Supply & Sanitation Division no. 3 Complex, Head Water works, Bhagu Road Bathinda
dwtlbathinda@gmail.com

To,

Principal
Different Convent School Badal Road Ghuddu , Bathinda

No.: DWTL/BTI/2627/00153 Dated : 04/07/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. dcs/spl/11 Dated: 03/07/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 03/07/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Bathinda

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory
Bathinda

DISTRICT WATER TESTING LABORATORY, BATHINDA
Water Supply & Sanitation Division no. 3 Complex, Head Water works, Bhagu Road Bathinda
dwtlbathinda@gmail.com

TEST REPORT


Name & Address of Customer : Principal Different Convent School Badal Road Ghuddu , Bathinda	Customer Reference No.	No : dcs/spl/11 Dated : 03/07/2026
	Sample Submitted by	Sh. Sonu Goyal
	Date of Sample Receipt	03/07/2026
	Analysis Starting Date	03/07/2026
	Analysis completion Date	04/07/2026
Discipline : Chemical Testing		Group: Water
ULR No.:	TC12834260000112F	Sample Type : Water
Test Report No.:	DWTL/BTI/2627/00153	Date of Issue : 04/07/2026
Registration no.:	DWTL/BTI/REG2627/00701	Condition of Sample : Sealed
Collection Point:	NA	Quantity/Type of Bottle: 1000 ml / NA
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth : Water Sample from Different Convent School Badal Road Ghuddu , Bathinda / NA
Village :	Ghudda	Habitation : Ghudda
Block:	Sangat	District : Bathinda
Latitude :	Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.02	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	BDL	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	88	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL(0.5)	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	36	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	72	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	10	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	12	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	16	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Bathinda

----- End of the Test Report -----

OFFICE CIVIL SURGEON BATHINDA

TO WHOM IT MAY CONCERN

Health & Sanitation Certificate

It is certified that on the request of President, Different Convent School, Village Ghudda (Bathinda) for granting Health and Sanitation Certificate. It is certified that the call-rooms and toilets are neat & clean. Overall sanitation is satisfactory as reported by the officer who was appointed to inspect physically. Drinking water samples taken on the same day was found fit for human consumption as reported by the Distt. Public Analyst (Chemically).

No. Mal./Tech./09/ 1856 .


Distt. Health Officer, 29/9/09